

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan


“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 12762-3 (1998): Photovoltaic Devices, Part 3:
Measurement Principles for Terrestrial Photovoltaic (PV)
Solar Devices with Reference Spectral Irradiance Data [ETD
28: Solar Photovoltaic Energy Systems]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



IS 12762 (Part 3) : 1998
IEC 904-3 (1989)

(Reaffirmed 2004)

भारतीय मानक

प्रकाशवोल्टीय युक्तियाँ

भाग 3 संदर्भ डाटा सहित स्थलीय प्रकाशवोल्टीय (पीवी) सौर युक्ति के लिये
मानक सिद्धांत की विशिष्टि

Indian Standard

PHOTOVOLTAIC DEVICES

**PART 3 MEASUREMENT PRINCIPLES FOR TERRESTRIAL PHOTOVOLTAIC (PV) SOLAR
DEVICES WITH REFERENCE SPECTRAL IRRADIANCE DATA**

ICS 27.160

BIS 1998

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

July 1998

Price Group 6

NATIONAL FOREWORD

This Indian Standard (Part 3) which is identical with IEC 904-3(1989) 'Photovoltaic devices — Part 3 : Measurement principles for terrestrial photovoltaic (PV) solar devices with reference spectral irradiance data' issued by the International Electrotechnical Commission (IEC) was adopted by the Bureau of Indian Standards on the recommendation of the Solar Photovoltaic Energy Systems Sectional Committee (ET 28) and approval of the Electrotechnical Division Council.

This standard describes measurement principles for determining the electrical performance of photovoltaic solar devices.

This standard has been issued in several parts. Other parts of this standard are:

- IS 12762 (Part 1) : 1989 Specification for photovoltaic devices : Part 1 Measurement of photovoltaic current-voltage characteristics
- IS 12762 (Part 2) : 1993 Specification for photovoltaic devices : Part 2 Requirements for references solar cells

Certain conventions appearing in this dual number standard are not identical to those used in Indian Standards. Attention is particularly drawn to the following:

- a) Wherever the words 'International Standard' appear referring to this standard, they should be read as 'Indian Standard'.
- b) Comma (,) has been used as a decimal marker while in Indian Standards, the current practice is to use a point (.) as the decimal marker.

Only the English language text in the IEC standard has been retained while adopting it in this Indian Standard.

For the purpose of deciding whether a particular requirement of this standard is complied with, final value observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS 2 : 1960 'Rules for rounding off numerical values (*revised*)'. The number of significant places retained in the rounded off value should be the same as that of the specified value in the standard.

Indian Standard

PHOTOVOLTAIC DEVICES

PART 3 MEASUREMENT PRINCIPLES FOR TERRESTRIAL PHOTOVOLTAIC (PV) SOLAR DEVICES WITH REFERENCE SPECTRAL IRRADIANCE DATA

1. Scope

This standard applies to the following crystalline silicon photovoltaic devices for terrestrial applications:

- a) single solar cells with or without a protective cover
- b) sub-assemblies of solar cells
- c) flat modules

Note. – The term “test specimen” is used to denote any of these devices.

This standard is not applicable to solar cells designed for operation in concentrated sunlight, to modules embodying concentrators, nor to hybrid collectors which in addition to generating electricity, transfer heat to fluids for use in thermal systems.

This standard describes measurement principles and specifies the reference spectral irradiance distribution.

Current-voltage characteristics and the derived parameters are explained.

2. Object

This standard specifies measurement principles for determining the electrical performance of the terrestrial photovoltaic solar devices defined in the scope. These principles cover testing in both natural and simulated sunlight.

3. Measurement principles

In current practice the photovoltaic performance of a solar cell or module is determined by exposing it at a known temperature to stable sunlight, natural or simulated, and tracing its current-voltage characteristic while measuring the magnitude of the incident irradiance. The measured performance is then corrected to Standard Test Conditions (STC) or other desired conditions of irradiance and temperature. The corrected power output at the rated voltage and STC is commonly referred to as the rated power.

Since a solar cell has a wavelength-dependent response, its performance is significantly affected by the spectral distribution of the incident radiation, which in natural sunlight varies with location, weather, time of year and time of day, and with a simulator varies with its type and conditions. If the irradiance is measured with a thermopile-type radiometer that is not spectrally selective, the measured conversion efficiencies can vary by several per cent due to spectral distribution changes.

The principles given in this standard are designed to reduce such discrepancies by relating the performance rating to a reference terrestrial solar spectral irradiance distribution.

This is done by measuring the irradiance with a reference device that has essentially the same relative spectral response as the test specimen, and has been calibrated in terms of short-circuit current per unit of irradiance (AW^{-1}m^2) with the reference spectral distribution.

The reference device automatically takes into account variations in the spectral distribution. Because of this, location and weather conditions are not critical when the reference device method is used for outdoor performance measurements. The type of simulator is not critical for indoor measurements. Moreover, since the time constants of both the reference device and the test specimen are similar, fluctuations in solar intensity can be accepted provided they do not occur during a measurement.

If the performance of a cell or module is related to a known spectral irradiance distribution, it is possible for a user or array designer, using the spectral response of the cells, to compute within a reasonable tolerance its performance when exposed to light of any other known spectral irradiance distribution.

4. Reference solar spectral irradiance distribution

The reference solar spectral irradiance distribution for the purposes of this standard is given in Table I and Figure 1. This is a total distribution (direct + diffuse) sunlight, corresponding to an irradiance of 1000 W m^{-2} at AM 1.5, on a plane surface tilted at 37° to the horizontal, with 0.2 ground reflectance albedo, under the following meteorological conditions:

- atmospheric water content: 1.42 cm
- atmosphere ozone content: 0.34 cm
- turbidity: 0.27 at $0.5 \mu\text{m}$

TABLE I
Reference solar spectral irradiance distribution

Wavelength	Spectral irradiance	Spectral photon irradiance	Cumulative integrated irradiance
μm	$\text{W m}^{-2} \cdot \mu\text{m}^{-1}$	$\text{cm}^{-2} \cdot \text{s}^{-1} \cdot \mu\text{m}^{-1}$	W m^{-2}
0,3050	9,5	1,459 E + 015	0,06
0,3100	42,3	6,602 E + 015	0,19
0,3150	107,8	1,710 E + 016	0,57
0,3200	181,0	2,916 E + 016	1,29
0,3250	246,8	4,038 E + 016	2,36
0,3300	395,3	6,567 E + 016	3,97
0,3350	390,1	6,579 E + 016	5,93
0,3400	435,3	7,451 E + 016	7,99
0,3450	438,9	7,623 E + 016	10,18
0,3500	483,7	8,523 E + 016	12,49
0,3600	520,3	9,430 E + 016	17,51
0,3700	666,2	1,241 E + 017	23,44
0,3800	712,5	1,363 E + 017	30,33
0,3900	720,7	1,415 E + 017	37,50
0,4000	1013,1	2,040 E + 017	46,17
0,4100	1158,2	2,391 E + 017	57,02
0,4200	1184,0	2,504 E + 017	68,74
0,4300	1071,9	2,320 E + 017	80,01
0,4400	1302,0	2,884 E + 017	91,88
0,4500	1526,0	3,457 E + 017	106,02
0,4600	1599,6	3,704 E + 017	121,65
0,4700	1581,0	3,741 E + 017	137,55
0,4800	1628,3	3,935 E + 017	153,60
0,4900	1539,2	3,797 E + 017	169,44
0,5000	1548,7	3,898 E + 017	184,88
0,5100	1586,5	4,074 E + 017	200,55
0,5200	1484,9	3,887 E + 017	215,91
0,5300	1572,4	4,196 E + 017	231,20
0,5400	1550,7	4,216 E + 017	246,81
0,5500	1561,5	4,324 E + 017	262,38
0,5700	1501,5	4,309 E + 017	293,01
0,5900	1395,5	4,145 E + 017	321,98
0,6100	1485,3	4,561 E + 017	350,78
0,6300	1434,1	4,549 E + 017	379,98
0,6500	1419,9	4,647 E + 017	408,52
0,6700	1392,3	4,696 E + 017	436,64
0,6900	1130,0	3,925 E + 017	461,86
0,7100	1316,7	4,707 E + 017	486,33
0,7180	1010,3	3,652 E + 017	495,64
0,7244	1043,2	3,805 E + 017	502,21
0,7400	1211,2	4,512 E + 017	519,79
0,7525	1193,9	4,523 E + 017	534,82
0,7575	1175,5	4,483 E + 017	540,75
0,7625	643,1	2,469 E + 017	545,29
0,7675	1030,7	3,983 E + 017	549,48
0,7800	1131,1	4,442 E + 017	562,99
0,8000	1081,6	4,356 E + 017	585,12
0,8160	849,2	3,489 E + 017	600,56
0,8237	785,0	3,255 E + 017	606,85
0,8315	916,4	3,836 E + 017	613,49
0,8400	959,9	4,059 E + 017	621,46
0,8600	978,9	4,238 E + 017	640,85
0,8800	933,2	4,134 E + 017	659,97
0,9050	748,5	3,410 E + 017	680,99
0,9150	667,5	3,075 E + 017	688,07
0,9250	690,3	3,215 E + 017	694,86
0,9300	403,6	1,890 E + 017	697,60
0,9370	258,3	1,218 E + 017	699,91

Wavelength	Spectral irradiance	Spectral photon irradiance	Cumulative integrated irradiance
μm	$\text{W m}^{-2} \cdot \mu\text{m}^{-1}$	$\text{cm}^{-2} \cdot \text{s}^{-1} \cdot \mu\text{m}^{-1}$	W m^{-2}
0,9480	313,6	1,497 E + 017	703,06
0,9650	526,8	2,559 E + 017	710,20
0,9800	646,4	3,189 E + 017	719,00
0,9935	746,8	3,735 E + 017	728,41
1,0400	690,5	3,615 E + 017	761,82
1,0700	637,5	3,434 E + 017	781,74
1,1000	412,6	2,285 E + 017	797,49
1,1200	108,9	6,140 E + 016	802,71
1,1300	189,1	1,076 E + 017	804,20
1,1370	132,2	7,567 E + 016	805,32
1,1610	339,0	1,981 E + 017	810,98
1,1800	460,0	2,733 E + 017	818,57
1,2000	423,6	2,559 E + 017	827,40
1,2350	480,5	2,988 E + 017	843,22
1,2900	413,1	2,683 E + 017	867,80
1,3200	250,2	1,663 E + 017	877,75
1,3500	32,5	2,209 E + 016	881,99
1,3950	1,6	1,124 E + 015	882,75
1,4425	55,7	4,045 E + 016	884,11
1,4625	105,1	7,738 E + 016	885,72
1,4770	105,5	7,845 E + 016	887,25
1,4970	182,1	1,372 E + 017	890,12
1,5200	262,6	2,010 E + 017	895,24
1,5390	274,2	2,125 E + 017	900,34
1,5580	275,0	2,157 E + 017	905,56
1,5780	244,6	1,943 E + 017	910,75
1,5920	247,4	1,983 E + 017	914,19
1,6100	228,7	1,854 E + 017	918,48
1,6300	244,5	2,006 E + 017	923,21
1,6460	234,8	1,946 E + 017	927,05
1,6780	220,5	1,863 E + 017	934,33
1,7400	171,5	1,502 E + 017	946,48
1,8000	30,7	2,782 E + 016	952,55
1,8600	2,0	1,873 E + 015	953,53
1,9200	1,2	1,160 E + 015	953,63
1,9600	21,2	2,092 E + 016	954,07
1,9850	91,1	9,104 E + 016	955,48
2,0050	26,8	2,705 E + 016	956,66
2,0350	99,5	1,019 E + 017	958,55
2,0650	60,4	6,279 E + 016	960,95
2,1000	89,1	9,420 E + 016	963,57
2,1480	82,2	8,889 E + 016	967,68
2,1980	71,5	7,912 E + 016	971,52
2,2700	70,2	8,023 E + 016	976,62
2,3600	62,0	7,367 E + 016	982,57
2,4500	21,2	2,615 E + 016	986,32
2,4940	18,5	2,323 E + 016	987,19
2,5370	3,2	4,087 E + 015	987,66
2,9410	4,4	6,515 E + 015	989,19
2,9730	7,6	1,138 E + 016	989,38
3,0050	6,5	9,834 E + 015	989,60
3,0560	3,2	4,923 E + 015	989,85
3,1320	5,4	8,515 E + 015	990,18
3,1560	19,4	3,082 E + 016	990,48
3,2040	1,3	2,097 E + 015	990,98
3,2450	3,2	5,228 E + 015	991,07
3,3170	13,1	2,188 E + 016	991,66
3,3440	3,2	5,387 E + 015	991,88
3,4500	13,3	2,310 E + 016	992,75
3,5730	11,9	2,141 E + 016	994,30
3,7650	9,8	1,858 E + 016	996,38
4,0450	7,5	1,527 E + 016	998,79
∞			1000,00

Note. – The cumulative integrated irradiance values were obtained by means of the modified trapezoidal integration technique.




FIG. 1. – Reference solar spectral irradiance distribution.

5. Current-voltage characteristics

One example of a current-voltage (I - V) curve measured at a fixed irradiance and temperature is shown in figure 2. The current is plotted along the ordinate, the voltage along the abscissa.

The electrical characteristics which may be derived from the I - V curve are:

- a) short-circuit current (I_{sc}): *Point A*
The current value where the I - V curve crosses the current axis at $V = 0$;
- b) open-circuit voltage (V_{oc}): *Point B*
The voltage value where the I - V curve crosses the voltage axis at $I = 0$;
- c) maximum power (P_{max}): *Point C*
The power at the point on the I - V curve where the product of current and voltage is maximum;
- d) load current (I_L): *Point D*
The measured current at a specified load voltage, V_L .




FIG. 2. – Example of current-voltage (I - V) curve.

APPENDIX A

TERMINOLOGY

A 1. Meteorological terminology

Solar elevation (θ)

Angle between the direct solar beam and the horizontal plane (degrees).

Air Mass (AM)

The length of path through the earth's atmosphere traversed by the direct solar beam, expressed as a multiple of the path traversed to a point at sea level with the sun directly overhead.

The value of "Air Mass" is 1 at sea level with cloudless sky when the sun is directly overhead and the air pressure $P = 1.013$ bar (760 mm Hg).

At any point, the value of the air-mass is given by:

$$AM = \frac{P}{P_0} \times \frac{1}{\sin \theta} \text{ with } P = \text{local air pressure in bar}$$

$$P_0 = 1.013 \text{ bar}$$

θ = solar elevation angle

Irradiance

Radiant power incident upon unit area of surface (Wm^{-2}).

Direct irradiance (direct insolation)

The radiant power from the sun's disk and from the circumsolar region of the sky within a subtended angle of 5° incident upon unit area (Wm^{-2}).

Diffuse irradiance

The radiant power from the whole of the sky, incident upon unit area (Wm^{-2}) except that contributing to the direct solar irradiance.

Global irradiance

Total radiant power incident upon unit area of a horizontal surface (Wm^{-2}) = direct irradiance (horizontal) + diffuse irradiance (horizontal).

Total irradiance

Total radiant power incident upon unit area of an inclined surface (Wm^{-2}).

Spectral irradiance (E_λ)

Irradiance per unit bandwidth at a particular wavelength ($\text{Wm}^{-2} \cdot \mu\text{m}^{-1}$).

Spectral photon irradiance ($E_{p\lambda}$)

Photon flux density at a particular wavelength ($\text{cm}^{-2} \cdot \text{s}^{-1} \cdot \mu\text{m}^{-1}$).

$$E_{p\lambda} = 5.035 \times 10^{14} \lambda E_\lambda \text{ (}\lambda \text{ in } \mu\text{m)}$$

Spectral irradiance distribution

Spectral irradiance plotted as a function of wavelength ($\text{Wm}^{-2} \cdot \mu\text{m}^{-1}$).

Irradiation

Integration of irradiance over a specified period of time (MJm^{-2} per hour, day, week, month, year as the case may be).

Direct irradiation

Integrated direct irradiance over a specified time period (MJm^{-2} per hour, per day, etc., as the case may be).

Diffuse irradiation

Integrated diffuse irradiance over a specified time interval (MJm^{-2} per hour, per day, etc., as the case may be).

Total irradiation

The integrated total irradiance over a specified time interval on a tilted surface (MJm^{-2} per day, week, etc., as the case may be).

Global irradiation

Integrated global irradiance over a specified time period (MJm^{-2} per hour, per day, etc., as the case may be).

Pyranometer

A radiometer normally used to measure global irradiance (or, with a shade ring or disc, diffuse irradiance) on a horizontal plane. Can also be used at an angle to measure the total irradiance on an inclined plane, which in this case includes an element due to radiation reflected from the foreground.

Pyrheliometer (sometimes called "Normal Incidence Pyrheliometer" or NIP)

A radiometer, completed with a collimator, used to measure direct irradiance.

Turbidity (a_D, λ)

The reduced transparency of the atmosphere, caused by absorption and scattering of radiation by solid or liquid particles, other than clouds, held in suspension. As defined by Ångström, the turbidity of the atmosphere is related to t , the extinction coefficient at a wavelength of 1 000 nm and to ϵ , the wavelength exponent in the expression for the aerosol extinction function:

$$a_{D, \lambda} = t \cdot \lambda^{-\epsilon}$$

t values less than 0.10 indicate a very clear condition, whereas values greater than 0.20 indicate a distinctly hazy condition. The average value of ϵ , which is dependent on the particle size distribution, was assumed by Ångström to be approximately 1.3.

Precipitable water vapour content

The volume of precipitable water vapour (cm^3) in a vertical column of the atmosphere 1 cm^2 in cross section expressed as the height of the corresponding vertical column of water (cm).

Ozone content

The volume of ozone (cm^3) at standard temperature and pressure in a vertical column of the atmosphere 1 cm^2 in cross section.

A 2. Photovoltaic physical parameters terminology

Solar cell

The basic photovoltaic device which generates electricity when exposed to sunlight.

Module

The smallest complete environmentally protected assembly of interconnected solar cells.

A 3. Photovoltaic conversion terminology

Photovoltaic effect

Direct conversion of radiant energy into electrical energy.

Conversion efficiency

The ratio of maximum electrical power output to the product of generator area and incident irradiance measured under defined test conditions and expressed as a percentage.

Spectral response ($S(\lambda)$)*

The short-circuit current density generated by unit irradiance at a particular wavelength (AW^{-1}), plotted as a function of wavelength.

Relative spectral response ($S(\lambda)_{\text{rel}}$)*

The spectral response normalized to unity at wavelength of maximum response.

$$S(\lambda)_{\text{rel}} = \frac{S(\lambda)}{S(\lambda)_{\text{max}}}$$

Short-circuit current (I_{sc})

The output current of a photovoltaic generator in the short-circuit condition at a particular temperature and irradiance.

Open-circuit voltage (V_{oc})

The voltage across an unloaded (open) photovoltaic generator at a particular temperature and irradiance.

Current-voltage characteristic ($I = f(V)$)

The output current of a photovoltaic generator as a function of output voltage, at a particular temperature and irradiance.

Maximum power (P_{max})

The power at the point on the current-voltage characteristic where the product of current and voltage is a maximum.

Maximum power voltage (V_{Pmax})

The voltage corresponding to maximum power.

Maximum power current (I_{Pmax})

The current corresponding to maximum power.

* The term "response" is commonly used but "responsivity" is strictly correct.

Fill factor (FF)

The ratio of maximum power to the product of open-circuit voltage and short-circuit current:

$$FF = \frac{P_{\max}}{V_{oc} \times I_{sc}}$$

Load current (I_L)

The current supplied by the PV generator at a particular temperature and irradiance, into a load connected across its terminals.

Load voltage (V_L)

The voltage appearing across the terminals of a load connected to the terminals of the PV generator at a particular temperature and irradiance.

Load power (P_L)

The power supplied to a load connected to the terminals of the PV generator at a particular temperature and irradiance.

$$P_L = V_L \times I_L$$

Rated current

The assigned value of current of a PV generator at the rated voltage under specified operating conditions.

Rated power

The assigned value of power output of a photovoltaic generator at rated voltage under specified operating conditions.

Rated voltage

The assigned value of voltage at which a photovoltaic generator is designed to provide near maximum electrical power under specified operating conditions.

Test irradiance

Irradiance used for test purposes, as measured with a reference device.

Standard Test Conditions (STC)

- Cell temperature: $25 \pm 2^\circ\text{C}$.
- Irradiance: As measured with a reference device: $1\,000\text{ Wm}^{-2}$ with the reference solar spectral irradiance distribution.

Optional test conditions

Test irradiance as measured with a reference device of $1\,000\text{ Wm}^{-2}$ and cell temperature at any convenient measured ambient conditions.

Ambient temperature (T_{amb})

The temperature of the air surrounding the photovoltaic generator as measured in a vented enclosure and shielded from solar, sky and ground radiation.

Module surface temperature

The mean temperature of the back surface of the module.

Cell temperature (T_j)

Directly measured by a thermal sensor in contact with the cell or derived from V_{oc} measurement or thermal balance calculations. It is not very different from the temperature of the cell exposed face.

Current temperature coefficient (α)

The change of the short-circuit current of a PV generator per degree Celsius change of cell temperature.

Note. – This coefficient varies with irradiance and to a lesser extent, with temperature.

Voltage temperature coefficient (β)

The change of the open circuit voltage of a PV device per degree Celsius change of cell temperature.

Note. – This coefficient varies with irradiance and to a lesser extent with temperature.

Nominal Operating Cell Temperature (NOCT)

The equilibrium mean solar cell temperature within a module in a standard reference environment of 800 Wm^{-2} irradiance, 20°C ambient air temperature, 1 ms^{-1} wind speed, electrically open-circuit and open rack mounted at normal incidence, at solar noon.

Time constant

The time required for a radiometer or photovoltaic generator to attain 63.2% of its steady state value after a step change of irradiance.

Angle of incidence

The angle between the direct irradiant beam and the normal to the active surface (degrees).

Reference device

A photovoltaic device used to measure irradiance or to set simulator irradiance levels in terms of a reference solar spectral irradiance distribution.

Bureau of Indian Standards

BIS is a statutory institution established under the *Bureau of Indian Standards Act, 1986* to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

Copyright

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publication), BIS.

Review of Indian Standards

Amendments are issued to standards as the need arises on the basis of comments. Standards are also reviewed periodically; a standard along with amendments is reaffirmed when such review indicates that no changes are needed; if the review indicates that changes are needed, it is taken up for revision. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition by referring to the latest issue of 'BIS Handbook' and 'Standards Monthly Additions'.

This Indian Standard has been developed from Doc: No. ET 28 (3762).

Amendments Issued Since Publication

Amend No.	Date of Issue	Text Affected

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002
Telephones: 323 01 31, 323 33 75, 323 94 02

Telegrams: Manaksanstha
(Common to all offices)

Regional Offices:

Telephone

Central : Manak Bhavan, 9 Bahadur Shah Zafar Marg
NEW DELHI 110002

323 76 17, 323 38 41

Eastern : 1/14 C.I.T. Scheme VII M, V.I.P. Road, Maniktola
CALCUTTA 700054

{ 337 84 99, 337 85 61
337 86 26, 337 91 20

Northern : SCO 335-336, Sector 34-A, CHANDIGARH 160022

{ 60 38 43
60 20 25

Southern : C.I.T. Campus, IV Cross Road, CHENNAI 600113

{ 235 02 16, 235 04 42
235 15 19, 235 23 15

Western : Manakalaya, E9 MIDC, Marol, Andheri (East)
MUMBAI 400093

{ 832 92 95, 832 78 58
832 78 91, 832 78 92

Branches : AHMADABAD. BANGALORE. BHOPAL. BHUBANESHWAR.
COIMBATORE. FARIDABAD. GHAZIABAD. GUWAHATI.
HYDERABAD. JAIPUR. KANPUR. LUCKNOW. NAGPUR.
PATNA. PUNE. THIRUVANANTHAPURAM.